



Compact e-RCB0

Domestic version



IEC 61009-1




WARNING!

Insulation tests only to be performed in the bottom terminals and with the device switched off





WARNING!

Reverse connection of the eRCB0 will cause damage

TEST



1 JAN.... 1 FE.... 1 MAR....
Test frequently



GE imagination at work